

2018 CONSUMER CONFIDENCE REPORT

Water Quality Data

Contaminant	MCLG in CCR Units	MCL in CCR Units	Level found in CCR Units	Range of detections	Violation	Date of sample
Microbiological Contaminants						
Total Coliform Bacteria	0	0	0		no	2017
Turbidity ***	N/A	95%<0.3NTU	0.29NTU	0.02-0.48NTU	no	2017
Inorganic Contaminants						
Copper (90th %) *	1.3	AL=1.3 ppm	0.17 ppm	0.00346 to 0.276 ppm	no	2015
Fluoride	4	4 ppm	.44ppm	0.37-0.50 ppm	no	2017
Lead (90th %) *	0	AL=15 ppb	.18 ppb	0 to .00206 PPM	no	2015
Arsenic	10	10 ppm	<1.0 PPB		no	2012
Sodium	N/A	N/A	11.2 ppm	5.9 -11.2 ppm	no	2017
Organic Contaminants						
Trihalomethanes (THMs)	0	80 ppb	32.9 ppb avg	15.2 ppb to 43.2 ppb	no	2017
Haloacetic Acid	0	60 ppb	29.18 ppb avg	17.0 ppb to 47.0 ppb	no	2017
Cryptosporidium	0		0 oocysts	0 oocysts per liter	no	2017
Chlorine	Mrdlg 4	Mrdl 4 ppm	1.76 ppm avg	0.7 ppm to 2.6 ppm	no	2017

* No Samples exceeded the action level for Lead and Copper

2018 CONSUMER CONFIDENCE REPORT

Water Quality Data

Typical source of Contaminant
Naturally present in the environment
Soil runoff
Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Erosion of natural deposits
Corrosion of household plumbing systems; Erosion of natural deposits
Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Naturally present in the environment
By-product of drinking water chlorination
By-product of drinking water disinfection
Naturally present in the environment
Disinfectant used in water treatment to inactivate microbial contaminants.